

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE 20 P C 427 PRJ - 02263371 Lighting				
CMPPA Directory Link	#N/A				
PA	PGE				
PA Application ID	PRJ - 02263371				
PA Application Executed Date	02/14/2020				
PA Program ID	PGE2110051				
PA Program Name	Local Government Energy Action Resources (LGEAR)				
PA Program Year	2020				
Date of CPUC Staff Review:	6/1/2020				
PA CMPA Upload Dates Included in this review:					
First PA Upload	3/17/2020				
Second PA Upload	N/A				
Third PA Upload	N/A				
PA Measure Description(s):					
Measure 1	Lighting Retrofit/New-Exterior-LED-Pole Mounted				
Measure 2	Lighting Retrofit/New-Exterior-LED-Wall Mounted				
Measure 3					
Measure 4					
Measure 5					
Measure 6					
Measure 7					
Measure 8					
Measure 9					
Measure 10					
PA Project Description:	replace MH or HPS with LED Exterior Fixture				
PA Ex Ante kW Demand Reduction	1.0				
PA Ex Ante Annual kWh Impacts	195,120.0				
PA Ex Ante Annual Therm Impacts	1.0				
PA Proposed Incentive \$ (to Customer)	\$19,951.10				
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0				
CPUC Staff Approved Ex Ante kW Demand Reduction					
CPUC Staff Approved Ex Ante Annual kWh Impacts					
CPUC Staff Approved Ex Ante Annual Therm Impacts					
CPUC Staff Primary Reviewer Name					
CPUC Staff Primary Reviewer Firm	SBW Consulting				
CPUC Staff Review Supervisor Name					
CPUC Staff Review Supervisor Firm	SBW Consulting				
PA Primary Reviewer Name					
PA Primary Reviewer Firm					
CPUC Staff Project Manager					
CPUC Staff Policy Authorization (as needed)					
CPUC Staff Recommendation Marked "X":					
X	Application ready to proceed without exception				
	Application ready to proceed with exception(s), as noted				
	Application rejected.				
	Application not ready for review, revised and resubmit as noted				
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date	PA Response	CPUC Response
1	Estimated annual savings of 195,119 kWh is greater than total building annual consumption of 112,548 kWh, based on utility bills submitted as part of the project package. The payback of the project before incentives is less than 1 year. Please update savings to include MLC v12 capping analysis.	Calculation method	Within one month of this disposition	With multiple elec meters at the premise, the project developer has re-run the savings analysis with MLV v12.1 using the non-IOU fuel source tab. Please thank the reviewer who might be able to revise the disposition based on the updated meter information.	Revised billing analysis is appropriate. Going forward, please provide back up utility bills to support data used in "Non-IOU Fuel Source Analysis" sheet.

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date		
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					

