

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE 20 P C 496 PRJ - 02374060 Lighting				
CMPA Directory Link	https://deeresources.info/cmpa/projects/17243				
PA	PGE				
PA Application ID	PRJ - 02374060				
PA Application Executed Date	NA				
PA Program ID	PGE211024				
PA Program Name	San Francisco Energy Watch				
PA Program Year					
Date of CPUC Staff Review:	7/15/2020				
PA CMPA Upload Dates Included in this review:					
First PA Upload	5/5/2020				
Second PA Upload	6/16/2020				
Third PA Upload	N/A				
PA Measure Description(s):					
Measure 1	Lighting Retrofit/New-Exterior-LED-Pole Mounted				
Measure 2					
Measure 3					
Measure 4					
Measure 5					
Measure 6					
Measure 7					
Measure 8					
Measure 9					
Measure 10					
PA Project Description:	NA				
PA Ex Ante kW Demand Reduction	0.0				
PA Ex Ante Annual kWh Impacts	42,246.4				
PA Ex Ante Annual Therm Impacts	0.0				
PA Proposed Incentive \$ (to Customer)	\$5,069.57				
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0				
CPUC Staff Approved Ex Ante kW Demand Reduction					
CPUC Staff Approved Ex Ante Annual kWh Impacts					
CPUC Staff Approved Ex Ante Annual Therm Impacts					
CPUC Staff Primary Reviewer Name					
CPUC Staff Primary Reviewer Firm	E350				
CPUC Staff Review Supervisor Name					
CPUC Staff Review Supervisor Firm	SBW				
PA Primary Reviewer Name					
PA Primary Reviewer Firm					
CPUC Staff Project Manager					
CPUC Staff Policy Authorization (as needed)					
CPUC Staff Recommendation Marked "X":					
X	Application ready to proceed without exception				
	Application ready to proceed with exception(s), as noted				
	Application rejected.				
	Application not ready for review, revised and resubmit as noted				
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date	PA Response	CPUC Staff Response
1	Please update the RUL of existing/baseline fixtures based on the EUL of the same type of equipment. The project is currently using the EUL of installed equipment (LED fixtures) to estimate the RUL of existing/baseline equipment (HIDs).	EUL/RUL	within 30 days of this disposition	updated RUL from 4 years to 5 years	This is correct - no other action is required.

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction	Due Date		
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					

