

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_20_T_C_506_PRJ - 02126476_Lighting
CPMA Directory Link	https://deeresources.info/cmpa/projects/17310
PA	PGE
PA Application ID	PRJ - 02126476
PA Application Executed Date	0
PA Program ID	a0n3600000NcVly
PA Program Name	Hospitality Program - Direct Install
PA Program Year	1900
Date of CPUC Staff Review:	6/23/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	6/2/2020
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	LIGHTING RETROFIT/NEW-INT LED HIGHBAY
Measure 2	LIGHTING RETROFIT/NEW-INT-LED-GENERAL/AREA LIGHTING
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	0
PA Ex Ante kW Demand Reduction	24.7
PA Ex Ante Annual kWh Impacts	101,930.1
PA Ex Ante Annual Therm Impacts	-49.7
PA Proposed Incentive \$ (to Customer)	\$15,936.62
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0
CPUC Staff Approved Ex Ante kW Demand Reduction	
CPUC Staff Approved Ex Ante Annual kWh Impacts	
CPUC Staff Approved Ex Ante Annual Therm Impacts	
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
	Application ready to proceed without exception
X	Application ready to proceed with exception(s), as noted
	Application rejected.
	Application not ready for review, revised and resubmit as noted

Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date
1	Please update the measure RUL to 1/3 of the existing equipment (linear fluorescent) EUL. The project uses 1/3 of EUL of installed fixtures (LEDs) as the RUL.	EUL/RUL	within 30 days of this disposition
2	The project package only includes pre-installation pictures. Going forward, please also provide post-installation pictures showing installed lighting fixtures.	Missing document	NA

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

