

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE 20 T C 506 PRJ - 02126476 Lighting				
CMPA Directory Link	https://deeresources.info/cmpa/projects/17310				
PA	PGE				
PA Application ID	PRJ - 02126476				
PA Application Executed Date	0				
PA Program ID	a0n3600000NcVly				
PA Program Name	Hospitality Program - Direct Install				
PA Program Year	1900				
Date of CPUC Staff Review:	6/23/2020				
PA CMPA Upload Dates Included in this review:					
First PA Upload	6/2/2020				
Second PA Upload	N/A				
Third PA Upload	N/A				
PA Measure Description(s):					
Measure 1	LIGHTING RETROFIT/NEW-INT LED HIGHBAY				
Measure 2	LIGHTING RETROFIT/NEW-INT-LED-GENERAL/AREA LIGHTING				
Measure 3					
Measure 4					
Measure 5					
Measure 6					
Measure 7					
Measure 8					
Measure 9					
Measure 10					
PA Project Description:	0				
PA Ex Ante kW Demand Reduction	24.7				
PA Ex Ante Annual kWh Impacts	101,930.1				
PA Ex Ante Annual Therm Impacts	-49.7				
PA Proposed Incentive \$ (to Customer)	\$15,936.62				
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0				
CPUC Staff Approved Ex Ante kW Demand Reduction					
CPUC Staff Approved Ex Ante Annual kWh Impacts					
CPUC Staff Approved Ex Ante Annual Therm Impacts					
CPUC Staff Primary Reviewer Name					
CPUC Staff Primary Reviewer Firm	E350				
CPUC Staff Review Supervisor Name					
CPUC Staff Review Supervisor Firm	SBW				
PA Primary Reviewer Name					
PA Primary Reviewer Firm					
CPUC Staff Project Manager					
CPUC Staff Policy Authorization (as needed)					
CPUC Staff Recommendation Marked "X":					
	Application ready to proceed without exception				
X	Application ready to proceed with exception(s), as noted				
	Application rejected.				
	Application not ready for review, revised and resubmit as noted				
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date	PA Response	Response Date

1	Please update the measure RUL to 1/3 of the existing equipment (linear fluorescent) EUL. The project uses 1/3 of EUL of installed fixtures (LEDs) as the RUL.	EUL/RUL	within 30 days of this disposition	Revised the MLC and upload to CMPA.	6/25/2020
2	The project package only includes pre-installation pictures. Going forward, please also provide post-installation pictures showing installed lighting fixtures.	Missing document	NA	The customer is unable to provide additional photos at this time due to shelter in place requirements. PG&E will continue to request post-install photos where businesses are still closed during CV-19 SIP mandates and upload these pictures when they become available.	NA

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date		
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					

