

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_20_P_C_509_PRJ - 02226315_Lighting
CPMA Directory Link	https://deeresources.info/cmpa/projects/17319
PA	PGE
PA Application ID	PRJ - 02226315
PA Application Executed Date	0
PA Program ID	a0n1R00001MaD4i
PA Program Name	LGEAR - Staples Direct Install
PA Program Year	1900
Date of CPUC Staff Review:	7/17/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	6/3/2020
Second PA Upload	6/30/2020
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	LIGHTING RETROFIT/NEW-INT-LED-OTHER
Measure 2	LIGHTING RETROFIT/NEW-INT-LED-GENERAL/AREA LIGHTING
Measure 3	LIGHTING RETROFIT/NEW-EXT-LED-POLE MOUNTED
Measure 4	LIGHTING RETROFIT/NEW-EXT-LED-WALL MOUNTED
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	0
PA Ex Ante kW Demand Reduction	2.6
PA Ex Ante Annual kWh Impacts	36,006.2
PA Ex Ante Annual Therm Impacts	-65.1
PA Proposed Incentive \$ (to Customer)	\$4,714.40
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0
CPUC Staff Approved Ex Ante kW Demand Reduction	
CPUC Staff Approved Ex Ante Annual kWh Impacts	
CPUC Staff Approved Ex Ante Annual Therm Impacts	
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	Energy 350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW Consulting
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
	Application ready to proceed without exception
X	Application ready to proceed with exception(s), as noted
	Application rejected.
	Application not ready for review, revised and resubmit as noted

Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date
1	Reported savings are larger than total building consumption. Looks like the PA limited savings to the total building consumption using monthly cap analysis in MLC but did not correct the reported savings. Please revise the savings for quarterly submission based on the monthly consumption cap analysis.	Analysis Assumptions	within 30 days of this disposition
2	Please update the RUL of existing equipment based on the EUL of the same type of equipment. Currently, the project uses EUL of installed equipment to estimate RUL of existing equipment.	EUL/RUL	within 30 days of this disposition

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

