

## CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_20_T_I_516_PRJ - 02367514_Service
CPMA Directory Link	<a href="https://deerresources.info/cmpa/projects/17340">https://deerresources.info/cmpa/projects/17340</a>
PA	PGE
PA Application ID	PRJ - 02367514
PA Application Executed Date	
PA Program ID	a0n3600000NcViO
PA Program Name	Industrial Recommissioning Program - Retro Commissioning (RCx)
PA Program Year	
Date of CPUC Staff Review:	7/20/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	6/9/2020
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 2	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 3	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 4	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 5	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 6	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 7	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 8	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 9	
Measure 10	
PA Project Description:	
PA Ex Ante kW Demand Reduction	24.1
PA Ex Ante Annual kWh Impacts	607,729.4
PA Ex Ante Annual Therm Impacts	6,316.6
PA Proposed Incentive \$ (to Customer)	\$36,945.31
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	24.1
CPUC Staff Approved Ex Ante Annual kWh Impacts	607,729.4
CPUC Staff Approved Ex Ante Annual Therm Impacts	6,316.6
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW Consulting
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	

<b>CPUC Staff Recommendation Marked "X":</b>		
<b>x</b>	Application ready to proceed without exception	
	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
<b>Action Number:</b>	<b>Summary of CPUC Staff Required Action by the PA:</b>	<b>Action Category</b>

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1	The HVAC calculator used to estimate savings has not been updated to account for the new definition for the DEER 2020 peak demand period. Please update.	Issue with Parameter Assumptions
2	The building type used (manufacturing light industrial) appears incorrect (the majority of the building is office space/non-industrial).	
3		
4		
5		
6		
7		
8		
9		
10		

