

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE 20 T 1 579 PRJ - 01942579 Process
CPMA Directory Link	https://deeresources.info/cmpa/projects/18806
PA	PGE
PA Application ID	PRJ - 01942579
PA Application Executed Date	
PA Program ID	PGE21027
PA Program Name	Heavy Industry Energy Efficiency Program - Customized Retrofit
PA Program Year	
Date of CPUC Staff Review:	11/24/2020
PA CMA Upload Dates Included in this review:	
First PA Upload	10/20/2020
Second PA Upload	11/3/2020
Third PA Upload	N/A
Fourth PA Upload	
Fifth PA Upload	
Sixth PA Upload	
Seventh PA Upload	
Eighth PA Upload	
PA Measure Description(s):	
Measure 1	PROCESS RETROFIT/NEW-COMPRESSED AIR-EFFICIENT AIR
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	0
Bi-Monthly Upload kW Demand Reduction	37.1
Bi-Monthly Upload Annual kWh Impacts	246,271.0
Bi-Monthly Upload Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$35,113.02
Project Documentation kW Demand Reduction	37.1
Project Documentation Annual kWh Impacts	246,271.0
Project Documentation Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	Energy 350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW Consulting
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation:	Application rejected.
For rejection, action required:	Complete Resubmittal Required (SB1131 timeline reset)
M&V Review:	Post M&V Review NOT Required

Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date	PA Response	ED Resolution
1	<p>According to the 2014 Statewide Air Compressor Program Guidelines (we will upload this document with this disposition), all compressed air projects for systems with more than one air compressor, where any compressor (normally operating or not normally operating) exceeds 50 HP and where the applicant claims that the project is exempt from Title 24 because the alteration does not exceed 50% of the online capacity, will require measurements to establish the online capacity requirements. When measurements are required, true power will be measured in one minute or less increments for two weeks on all system compressors whether they are normally operating or not. Any air compressor found to be operating unloaded during the measurement period will be considered to be a backup compressor for the purposes of determining the system online capacity requirement. True power measurements are required, measurements of compressor amps alone are not sufficient. All raw data and the analysis of the data should be included in the application documentation. Please redo baseline measurements according to this guidance and resubmit the project.</p>	Baseline	N/A		

CPUC Staff Recommendation Definitions	
CPUC Staff Recommendation	Definition
Application ready to proceed without exception	The PA will continue to upload application documents to the CMPA directory through the implementation and claims phases of the project. The PA may proceed to approve the project without waiting for CPUC Staff response. A project is waived from further review at the post-installation stage by CPUC staff, but the PA is responsible for post-installation (IR) review. There will not be conditional approval.
Application ready to proceed with exception(s), as noted	<p>The PA must make revisions or changes as noted in CPUC Staff's review comments. The PA will continue to upload application documents to the CMPA directory through the implementation and claims phases of the project. The PA may proceed to approve the project without waiting for CPUC Staff response. If CPUC Staff decides to perform IR review of a project, CPUC Staff will notify the PA. The scope will be limited to determine if the project was carried out consistent with the application and notes provided during pre-installation review and to obtain information pertaining to whether the eligibility criteria or metrics should be revised.</p> <p>Unless the scope of work presented in project application has changed at IR review, the project will not be reviewed again in the areas specified below. Scope change is defined by substantial changes include significant modifications to the proposed equipment type, size, quantity, configuration, the expansion of a project to include additional retrofits, or the splitting of a project into multiple phases.</p> <p>The following areas will not be reviewed again by CPUC Staff:</p> <ul style="list-style-type: none"> • Calculation Tool • Calculation Methodology • M&V Plan • Baseline • Eligibility • EUL/RUL • Measure Type • Program Influence
Application rejected.	<p>The application is rejected as submitted. The PA shall promptly inform the applicant as to the reasons why the project was rejected and the specific recommendations for the conditions under which the project would be approved. CPUC Staff shall provide the reasons for the rejection or request for modification, including each basis as to why the project is rejected, or modification is requested. In addition, CPUC Staff shall provide specific recommendations for the conditions under which the project would be approved.</p> <p>If any party to the project is unsatisfied with the Commission's directions for the project, a dispute resolution process may be initiated by that party. The Commission shall adopt rules for the conduct of the dispute resolution process. – Section 381.2 (g) (3) (F)</p>