

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE 20 C C 537 PRJ - 02040067 Service
CMPA Directory Link	https://deeresources.info/cmpa/projects/18630
PA	PGE
PA Application ID	
PA Application Executed Date	
PA Program ID	a0n3600000NcVkp
PA Program Name	Commercial Calculated Incentives - Customized Incentive Program
PA Program Year	
Date of CPUC Staff Review:	10/21/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	8/4/2020
Second PA Upload	9/22/2020
Third PA Upload	N/A
Fourth PA Upload	
Fifth PA Upload	
Sixth PA Upload	
Seventh PA Upload	
Eighth PA Upload	
PA Measure Description(s):	
Measure 1	COMMISSIONING-RCX RECODE CONTROLS-HVAC-AIRFLOW
Measure 2	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SCHEDULE CHANGE
Measure 3	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 4	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	0
Bi-Monthly Upload kW Demand Reduction	145.0
Bi-Monthly Upload Annual kWh Impacts	1,519,642.0
Bi-Monthly Upload Therm Impacts	164,763.0
PA Proposed Incentive \$ (to Customer)	\$175,817.76
Project Documentation kW Demand Reduction	145.0
Project Documentation Annual kWh Impacts	1,519,642.0
Project Documentation Annual Therm Impacts	164,763.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation:	Application ready to proceed with exception(s), as noted
For rejection, action required:	N/A
M&V Review:	Post M&V Review (M&V Results and Final Calculations) Required

Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date	PA Response	ED
1	We would like to review this project at post installation once the eQUEST model has been updated with post M&V data. For post M&V review, please provide M&V data, updated model (including BIN weather file), invoices, and any project documents that are modified. Please also provide as-built/construction dwgs and/or an as-built sequence of operations.	M&V plan			
2	The HVAC Tool Rev03 is mentioned throughout project documentation, however eQUEST appears to be used to estimate savings for all four measures. Please confirm.	Calculation method			

CPUC Staff Recommendation Definitions	
CPUC Staff Recommendation	Definition
Application ready to proceed without exception	The PA will continue to upload application documents to the CMPA directory through the implementation and claims phases of the project. The PA may proceed to approve the project without waiting for CPUC Staff response. A project is waived from further review at the post-installation stage by CPUC staff, but the PA is responsible for post-installation (IR) review. There will not be conditional approval.
Application ready to proceed with exception(s), as noted	<p>The PA must make revisions or changes as noted in CPUC Staff's review comments. The PA will continue to upload application documents to the CMPA directory through the implementation and claims phases of the project. The PA may proceed to approve the project without waiting for CPUC Staff response. If CPUC Staff decides to perform IR review of a project, CPUC Staff will notify the PA. The scope will be limited to determine if the project was carried out consistent with the application and notes provided during pre-installation review and to obtain information pertaining to whether the eligibility criteria or metrics should be revised.</p> <p>Unless the scope of work presented in project application has changed at IR review, the project will not be reviewed again in the areas specified below. Scope change is defined by substantial changes include significant modifications to the proposed equipment type, size, quantity, configuration, the expansion of a project to include additional retrofits, or the splitting of a project into multiple phases.</p> <p>The following areas will not be reviewed again by CPUC Staff:</p> <ul style="list-style-type: none"> • Calculation Tool • Calculation Methodology • M&V Plan • Baseline • Eligibility • EUL/RUL • Measure Type • Program Influence
Application rejected.	<p>The application is rejected as submitted. The PA shall promptly inform the applicant as to the reasons why the project was rejected and the specific recommendations for the conditions under which the project would be approved. CPUC Staff shall provide the reasons for the rejection or request for modification, including each basis as to why the project is rejected, or modification is requested. In addition, CPUC Staff shall provide specific recommendations for the conditions under which the project would be approved.</p> <p>If any party to the project is unsatisfied with the Commission's directions for the project, a dispute resolution process may be initiated by that party. The Commission shall adopt rules for the conduct of the dispute resolution process. – Section 381.2 (g) (3) (F)</p>