

CPUC Staff Ex Ante Review

| | |
|---|---|
| CPUC Staff Project ID Number | PGE_21_T_C_706_PRJ - 03210524_Lighting |
| CMPPA Directory Link | https://deeresources.info/cmpa/projects/19251 |
| PA | PGE |
| PA Application ID | PRJ - 03210524 |
| PA Application Executed Date | |
| PA Program ID | PGE210143 |
| PA Program Name | Hospitality Program - Custom Direct Install |
| PA Program Year | |
| Date of CPUC Staff Review: | 11/30/2021 |
| PA CMPA Upload Dates Included in this review: | |
| First PA Upload | 10/19/2021 |
| Second PA Upload | N/A |
| Third PA Upload | N/A |
| Fourth PA Upload | |
| Fifth PA Upload | |
| Sixth PA Upload | |
| Seventh PA Upload | |
| Eighth PA Upload | |
| PA Measure Description(s): | |
| Measure 1 | LIGHTING RETROFIT/NEW-EXT-LED-CANOPY |
| Measure 2 | LIGHTING RETROFIT/NEW-INT-LED-RECESSED DOWNLIGHTS |
| Measure 3 | LIGHTING RETROFIT/NEW-EXT-LED-OTHER |
| Measure 4 | LIGHTING RETROFIT/NEW-EXT-LED-WALL MOUNTED |
| Measure 5 | LIGHTING RETROFIT/NEW-INT-LED-GENERAL/AREA LIGHTING |
| Measure 6 | LIGHTING RETROFIT/NEW-INT LED HIGHBAY |
| Measure 7 | LIGHTING RETROFIT/NEW-EXT-LED-POLE MOUNTED |
| Measure 8 | |
| Measure 9 | |
| Measure 10 | |
| PA Project Description: | Interior and Exterior LED Lighting Upgrade, replacing CFL, T5/T8 linear fluorescent and HID fixtures |
| Bi-Monthly Upload kW Demand Reduction | 15.5 |
| Bi-Monthly Upload Annual kWh Impacts | 283,372.0 |
| Bi-Monthly Upload Therm Impacts | -636.6 |
| PA Proposed Incentive \$ (to Customer) | \$35,560.59 |
| Project Documentation kW Demand Reduction | 18.9 |
| Project Documentation Annual kWh Impacts | 308,691.6 |
| Project Documentation Annual Therm Impacts | -837.2 |
| CPUC Staff Primary Reviewer Name | |
| CPUC Staff Primary Reviewer Firm | SBW |
| CPUC Staff Review Supervisor Name | |
| CPUC Staff Review Supervisor Firm | SBW |
| PA Primary Reviewer Name | |
| PA Primary Reviewer Firm | |
| CPUC Staff Project Manager | |
| CPUC Staff Policy Authorization (as needed) | |
| CPUC Staff Recommendation: | Application ready to proceed with exception(s), as noted |
| For rejection, action required: | N/A |
| M&V Review: | Post M&V Review NOT Required |

| Action Number: | Summary of CPUC Staff Required Action by the PA: | Action Category | PA Response | ED Resolution |
|----------------|--|----------------------|-------------|---------------|
| 1 | There are some discrepancies between savings included in the bi-monthly upload and savings calculated in the project documentation (see above for Bi-Monthly Upload and Project Documentation savings values). We also found some errors in the calculations where MLC used incorrect measure codes. There are exterior fixtures that are assigned the "CLA42-Lighting Retrofit/New-Interior-LED-General/Area Lighting" measure code. Please correct these errors before claiming savings. | Analysis assumptions | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

| Note or Instruction Number: | CPUC Staff Notes or Instructions: | Instruction Category | PA Response | ED Resolution |
|-----------------------------|-----------------------------------|----------------------|-------------|---------------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

| CPUC Staff Recommendation Definitions | |
|--|--|
| CPUC Staff Recommendation | Definition |
| Application ready to proceed without exception | The PA will continue to upload application documents to the CMPA directory through the implementation and claims phases of the project. The PA may proceed to approve the project without waiting for CPUC Staff response. A project is waived from further review at the post-installation stage by CPUC staff, but the PA is responsible for post-installation (IR) review. There will not be conditional approval. |
| Application ready to proceed with exception(s), as noted | <p>The PA must make revisions or changes as noted in CPUC Staff's review comments before signed agreement with customer. The PA will continue to upload application documents to the CMPA directory through the implementation and claims phases of the project. The PA may proceed to approve the project without waiting for CPUC Staff response. If CPUC Staff decides to perform IR review of a project, CPUC Staff will notify the PA. The scope will be limited to determine if the project was carried out consistent with the application and notes provided during pre-installation review and to obtain information pertaining to whether the eligibility criteria or metrics should be revised.</p> <p>Unless the scope of work presented in project application has changed at IR review, the project will not be reviewed again in the areas specified below. Scope change is defined by substantial changes include significant modifications to the proposed equipment type, size, quantity, configuration, the expansion of a project to include additional retrofits, or the splitting of a project into multiple phases.</p> <p>The following areas will not be reviewed again by CPUC Staff:</p> <ul style="list-style-type: none"> • Calculation Tool • Calculation Methodology • M&V Plan • Baseline • Eligibility • EUL/RUL • Measure Type • Program Influence |
| Application rejected. | <p>The application is rejected as submitted. The PA shall promptly inform the applicant as to the reasons why the project was rejected and the specific recommendations for the conditions under which the project would be approved. CPUC Staff shall provide the reasons for the rejection or request for modification, including each basis as to why the project is rejected, or modification is requested. In addition, CPUC Staff shall provide specific recommendations for the conditions under which the project would be approved.</p> <p>If any party to the project is unsatisfied with the Commission's directions for the project, a dispute resolution process may be initiated by that party. The Commission shall adopt rules for the conduct of the dispute resolution process. – Section 381.2 (g) (3) (F)</p> |