

## **Final Phase II Ex Ante Review Findings**

**Table Error! No text of specified style in document.-1: Project Information**

<b>IOU</b>	PG&E
<b>Application ID</b>	SFEW0124
<b>Application Date</b>	4/29/2013
<b>Program ID</b>	PGE211024
<b>Program Name</b>	SF Energy Watch
<b>Program Year</b>	2013
<b>Itron Project ID</b>	X354
<b>IOU Ex Ante Savings Date</b>	9/19/2013
<b>ED Measure Name</b>	LED Lighting Retrofit
<b>Project Description</b>	Retrofit of CFL and LF Fixtures with 2x2 LED Fixtures
<b>Date of ED Review(s)</b>	6/25/2013 & 9/20/2013
<b>Primary Reviewer / Firm</b>	Ben Cheah & Leonel Campoy / Itron
<b>Review Supervisor / Firm</b>	Joseph Ball / Itron
<b>ED Project Manager</b>	██████████ / California Public Utilities Commission, Energy Division
<b>ED Policy Authorization (as needed)</b>	
<b>Type of Review (Desk, On-site, Full M&amp;V, Tool)</b>	Desk
<b>ED Recommendation</b>	The IOU-trued-up savings are approved at 58,949 kWh and 21.74 peak kW.

**Measure Description**

The installation of 493 2x2 LED troffer fixtures. The full project costs for the RUL period are \$162,922.21, the incremental costs for the EUL – RUL period are \$86,839.56, and the incentives are \$17,811.20.

**Review Conclusion**

ED approves the final IOU trued-up ex ante energy savings estimates of 58,949 kWh and 21.74 peak kW.

**Summary of ED Requested Action by the IOU**

None