

CPUC Staff Ex Ante Review

| | |
|---|---|
| CPUC Staff Project ID Number | PGE_19_C_C_237_PRJ - 01552578_CompAir |
| CPMA Directory Link | https://deeresources.info/cmpa/projects/15403 |
| PA | PGE |
| PA Application ID | PRJ - 01552578 |
| PA Application Executed Date | 43656 |
| PA Program ID | PGE21011 |
| PA Program Name | Commercial Calculated Incentives - Customized Incentive Program |
| PA Program Year | 2019 |
| Date of CPUC Staff Review: | 11/12/2019 |
| PA CMPA Upload Dates Included in this review: | |
| First PA Upload | 10/9/2019 |
| Second PA Upload | N/A |
| Third PA Upload | N/A |
| PA Measure Description(s): | |
| Measure 1 | PROCESS COMPRESSED AIR - ADD CONTROLS - To-Code/Std |
| Measure 2 | HVAC PUMPS - CHILLED WATER - FLOW CONFIGURATION - To-Code/Std |
| Measure 3 | HVAC EXHAUST/VENTILATION - BLDG DISTRIB FANS VFD - To-Code/Std |
| Measure 4 | COMMISSIONING-RCX RESET CONTROL SETTING-HVAC-SCHEDULE |
| Measure 5 | COMMISSIONING-RCX RESET CONTROL SETTING-HVAC-SCHEDULE |
| Measure 6 | COMMISSIONING-RCX RESET CONTROL SETTING-HVAC-SETPOINT |
| Measure 7 | COMMISSIONING-RCX RESET CONTROL SETTING-HVAC- |
| Measure 8 | COMMISSIONING-RCX RESET CONTROL SETTING-HVAC-AIRFLOW |
| Measure 9 | COMMISSIONING-RCX RESET CONTROL SETTING-HVAC-HYDRONIC |
| Measure 10 | COMMISSIONING-RCX RESET CONTROL SETTING-PROCESS-OTHER |
| PA Project Description: | RCx for (3) large office/production buildings in Milpitas |
| PA Ex Ante kW Demand Reduction | 63.8 |
| PA Ex Ante Annual kWh Impacts | 611,868.2 |
| PA Ex Ante Annual Therm Impacts | 5,312.9 |
| PA Proposed Incentive \$ (to Customer) | \$32,702.57 |
| PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer) | 0 |
| CPUC Staff Approved Ex Ante kW Demand Reduction | 45.7 |
| CPUC Staff Approved Ex Ante Annual kWh Impacts | 562,256.0 |
| CPUC Staff Approved Ex Ante Annual Therm Impacts | 4,779.9 |
| CPUC Staff Primary Reviewer Name | |
| CPUC Staff Primary Reviewer Firm | Sugarpine |
| CPUC Staff Review Supervisor Name | |
| CPUC Staff Review Supervisor Firm | BMI |
| PA Primary Reviewer Name | |
| PA Primary Reviewer Firm | |
| CPUC Staff Project Manager | |
| CPUC Staff Policy Authorization (as needed) | |
| CPUC Staff Recommendation Marked "X": | |
| | Application ready to proceed without exception |
| x | Application ready to proceed with exception(s), as noted |
| | Application rejected. |
| | Application not ready for review, revised and resubmit as noted |

| Action Number: | Summary of CPUC Staff Required Action by the PA: | Action Category | Due Date |
|----------------|---|-----------------|----------|
| 1 | VFDs on HVAC fans < 100 hp are not eligible for custom program incentives. Please remove ineligible measure and recalculate incentive | Eligibility | |
| | | | |
| | | | |

| Note or Instruction Number: | CPUC Staff Notes or Instructions: | Instruction Category | Due Date |
|-----------------------------|-----------------------------------|----------------------|----------|
| 1 | | | |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |

