

## CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_P_C_217_PMN-2019-057_Lighting
CPMA Directory Link	<a href="https://deeresources.info/cmpa/projects/15374">https://deeresources.info/cmpa/projects/15374</a>
PA	PGE
PA Application ID	PRJ - 01951325
PA Application Executed Date	5/10/2019
PA Program ID	PGE2110051
PA Program Name	LGEAR - TEAA Custom DI
PA Program Year	2019
Date of CPUC Staff Review:	10/8/2019
PA CMPA Upload Dates Included in this review:	
First PA Upload	8/20/2019
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	LIGHTING RETROFIT/NEW-EXT-LED-POLE MOUNTED
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Replace 110 exterior HID lighting fixtures (MH1000 Watt) with 110 DLC approved, Antec Lighting INC fixtures, qualified on 3.18.19; Product ID PC6E4NHL.
PA Ex Ante kW Demand Reduction	0.0
PA Ex Ante Annual kWh Impacts	381,546.0
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$61,047.36
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	0.0
CPUC Staff Approved Ex Ante Annual kWh Impacts	381,546.0
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	Sugarpine
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	BMI
PA Primary Reviewer Name	
PA Primary Reviewer Firm	

<b>CPUC Staff Project Manager</b>		
<b>CPUC Staff Policy Authorization (as needed)</b>		
<b>CPUC Staff Recommendation Marked "X":</b>		
<input checked="" type="checkbox"/>	Application ready to proceed without exception	
<input type="checkbox"/>	Application ready to proceed with exception(s), as noted	
<input type="checkbox"/>	Application rejected.	
<input type="checkbox"/>	Application not ready for review, revised and resubmit as noted	
<b>Action Number:</b>	<b>Summary of CPUC Staff Required Action by the PA:</b>	<b>Action Category</b>

<b>Note or Instruction Number:</b>	<b>CPUC Staff Notes or Instructions:</b>	<b>Instruction Category</b>
1	Energy Insight Project Page uploaded in the project documentation package was for a different project. Please check the documentation assembly process and reconcile problem going forward.	Missing documenation

