

## CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_P_C_292_PRJ - 02113963 Prop 39
CPMA Directory Link	<a href="https://deeresources.info/cmpa/projects/15693">https://deeresources.info/cmpa/projects/15693</a>
PA	PGE
PA Application ID	PRJ - 02113963
PA Application Executed Date	43745
PA Program ID	PGE211013
PA Program Name	MEWP (DI) - Custom Lite
PA Program Year	2019
Date of CPUC Staff Review:	1/14/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	11/7/2019
Second PA Upload	11/26/2019
Third PA Upload	1/8/2020
PA Measure Description(s):	
Measure 1	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 2	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 3	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 4	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 5	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 6	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 7	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 8	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 9	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 10	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
PA Project Description:	T8s to TLEDs
PA Ex Ante kW Demand Reduction	3.4
PA Ex Ante Annual kWh Impacts	97,272.9
PA Ex Ante Annual Therm Impacts	-1,205.4
PA Proposed Incentive \$ (to Customer)	\$12,178.06
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0
CPUC Staff Approved Ex Ante kW Demand Reduction	3.4
CPUC Staff Approved Ex Ante Annual kWh Impacts	97,272.9
CPUC Staff Approved Ex Ante Annual Therm Impacts	-1,205.4
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW Consulting
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	Energy 350
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	

CPUC Staff Recommendation Marked "X":		
		Application ready to proceed without exception
		Application ready to proceed with exception(s), as noted
	x	Application rejected.
		Application not ready for review, revised and resubmit as noted
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category
1	The non-IOU analysis needs to be corrected to follow the guideline in "EnergyEfficiency_Savings_at_Sites_with_non-IOU_Fuel_Sources_2015-11-06.pdf" scenario 9. As submitted, the non-IOU analysis is missing the monthly values for each of the following scenarios: 1) "no EE installed without the PV system installed" 2) "EE installed without the PV installed" and 3) "EE not installed with the PV system installed, ignoring export in monthly total use."	Non-IOU Energy Source not Accounted For
2	Please provide a memo supporting approval for the customer to proceed with installation prior to project approval	Project authorization
3	Reconcile the savings between the non-IOU analysis and the bi-monthly upload	Estimaed savings do not match

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		

