

## CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_P_C_340_PRJ - 02156274 Prop 39
CMPA Directory Link	<a href="https://deeresources.info/cmpa/projects/15804">https://deeresources.info/cmpa/projects/15804</a>
PA	PGE
PA Application ID	PRJ - 02156274
PA Application Executed Date	11/1/2019
PA Program ID	PGE211007
PA Program Name	AMBAG EW 2016-19
PA Program Year	2019
Date of CPUC Staff Review:	4/7/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	12/2/2019
Second PA Upload	#N/A
Third PA Upload	#N/A
PA Measure Description(s):	
Measure 1	Lighting Retrofit/New-Interior-LED-General/Area Lighting
Measure 2	Targeted Linear LED T8 Lamp Type Retrofit Kits
Measure 3	Lighting Retrofit/New-Interior-LED-Recessed Downlights
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Replaced/Retrofit (23) CFL Bi-Pin (2) 40W with (23) LED Troffer Kit 2x2
PA Ex Ante kW Demand Reduction	16.4
PA Ex Ante Annual kWh Impacts	45,669.7
PA Ex Ante Annual Therm Impacts	-338.2
PA Proposed Incentive \$ (to Customer)	\$12,218.90
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0
CPUC Staff Approved Ex Ante kW Demand Reduction	18.4
CPUC Staff Approved Ex Ante Annual kWh Impacts	51,245.5
CPUC Staff Approved Ex Ante Annual Therm Impacts	-379.7
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW Consulting
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	BMI
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
<input checked="" type="checkbox"/>	Application ready to proceed without exception
<input type="checkbox"/>	Application ready to proceed with exception(s), as noted
<input type="checkbox"/>	Application rejected.
<input type="checkbox"/>	Application not ready for review, revised and resubmit as noted

Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1	The following was part of the 01/21/2020 disposition that was corrected with a completed PA response document package, submitted on 3/18/2020. For note purposes the following was given as rejection on the 1/21/2020 disposition: "Input errors noted in MLC. Several of the proposed Generic LED fixtures were inadvertently assigned 22W rather than 23W, and the climate zone was assigned as CZ 3 rather than CZ4. Please revise the MLC and resubmit." Evidence was submitted to substantiate the fixture watts assumption, and the climate zone was updated. CS have no further issues with this project.	Analysis Assumptions	n/a
2			
3			
4			
5			
6			
7			
8			
9			
10			

