

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_P_C_353_PRJ - 02168306 Lighting
CPMA Directory Link	https://deeresrouces.info/cmpa/projects/15867
PA	PGE
PA Application ID	PRJ - 02168306
PA Application Executed Date	12/02/2019
PA Program ID	PGE211029
PA Program Name	Solano County Energy Watch
PA Program Year	2019
Date of CPUC Staff Review:	2/11/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	12/24/2019
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	Lighting Retrofit/New-Interior-LED-Recessed Downlights
Measure 2	Lighting Retrofit/New-Interior-LED-General/Area Lighting
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	HID lamp and ballast: 250 Watt Metal Halide lamp (1); NoSpec Ballast (1), Total fixture Watts = 295; Exterior Rated / LED fixture: Any Fixture Type, 15 watts, 620 Lumens
PA Ex Ante kW Demand Reduction	5.1
PA Ex Ante Annual kWh Impacts	18,689.2
PA Ex Ante Annual Therm Impacts	-113.2
PA Proposed Incentive \$ (to Customer)	\$4,506.65
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	5.1
CPUC Staff Approved Ex Ante Annual kWh Impacts	18,689.2
CPUC Staff Approved Ex Ante Annual Therm Impacts	-113.2
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW
PA Primary Reviewer Name	
PA Primary Reviewer Firm	

CPUC Staff Project Manager		
CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
	Application ready to proceed without exception	
x	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category
	MLC savings do not match Bi-monthly upload. Please reconcile.	Bi-monthly upload
	<p>Based on information provided it appears from what we were able to estimate (using a calculation provided for PGE_19_P_C_351_PRJ - 02142283_Lighting) that the simple payback period is less than the EUL (SPB=0).</p> <p>However, we would like to request that this calculation be provided in project documentation going forward for all MLC projects.</p>	EUL/RUL

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
-----------------------------	-----------------------------------	----------------------

