

## CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_P_C_364_PRJ - 02182884 Lighting
CPMA Directory Link	<a href="https://deerresources.info/accounts/login?next=/cmpa/projects/15886">https://deerresources.info/accounts/login?next=/cmpa/projects/15886</a>
PA	PGE
PA Application ID	PRJ - 02182884
PA Application Executed Date	12/09/2019
PA Program ID	PGE211007
PA Program Name	AMBAG EW 2016-19
PA Program Year	2019
Date of CPUC Staff Review:	3/17/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	1/14/2020
Second PA Upload	2/4/2020
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	Lighting Retrofit/New-Exterior-LED-Pole Mounted
Measure 2	Lighting Retrofit/New-Exterior-LED-Wall Mounted
Measure 3	Lighting Retrofit/New-Exterior-LED-Other
Measure 4	Basic Linear LED T8 Replacement Lamps & Non-Dimming Retrofit Kits
Measure 5	Lighting Retrofit/New-Interior-LED-Recessed Downlights
Measure 6	Lighting Retrofit/New-Interior-LED-General/Area Lighting
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Replaced/Retrofit (1) HPS 250w 1L with (1) LED Area 80w 5000K Type 5 (400w HID) NBAL NebuLite at a Assembly (ASM) facility
PA Ex Ante kW Demand Reduction	3.4
PA Ex Ante Annual kWh Impacts	34,468.1
PA Ex Ante Annual Therm Impacts	-151.0
PA Proposed Incentive \$ (to Customer)	\$6,545.62
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	3.4
CPUC Staff Approved Ex Ante Annual kWh Impacts	34,468.1
CPUC Staff Approved Ex Ante Annual Therm Impacts	-151.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW
PA Primary Reviewer Name	
PA Primary Reviewer Firm	

<b>CPUC Staff Project Manager</b>		
<b>CPUC Staff Policy Authorization (as needed)</b>		
<b>CPUC Staff Recommendation Marked "X":</b>		
<input checked="" type="checkbox"/>	Application ready to proceed without exception	
<input type="checkbox"/>	Application ready to proceed with exception(s), as noted	
<input type="checkbox"/>	Application rejected.	
<input type="checkbox"/>	Application not ready for review, revised and resubmit as noted	
<b>Action Number:</b>	<b>Summary of CPUC Staff Required Action by the PA:</b>	<b>Action Category</b>

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		

