

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_T_A_336_PRJ - 01018208_HVAC
CPMA Directory Link	https://deeresrouces.info/cmpa/projects/15800
PA	PGE
PA Application ID	PRJ - 01018208
PA Application Executed Date	11/1/2019
PA Program ID	PGE210312
PA Program Name	CLEAResult Dairy & Winery Industry Efficiency Solutions Program
PA Program Year	2019
Date of CPUC Staff Review:	1/21/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	12/3/2019
Second PA Upload	#N/A
Third PA Upload	#N/A
PA Measure Description(s):	
Measure 1	PROCESS RETROFIT/NEW-FAN-EFFICIENT UNIT
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Install a total of (90) 72-inch high efficiency fans in north, central and
PA Ex Ante kW Demand Reduction	0.0
PA Ex Ante Annual kWh Impacts	74,563.3
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$8,947.60
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	0.0
CPUC Staff Approved Ex Ante Annual kWh Impacts	74,563.3
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	BMI
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
	Application ready to proceed without exception
x	Application ready to proceed with exception(s), as noted
	Application rejected.
	Application not ready for review, revised and resubmit as noted

Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date
1	Project savings based on an estimate of the fan operating hours. PA project review states post-installation M&V will be conducted, but the M&V plan was not submitted. Please confirm M&V will be conducted on this project and re-submit the project for review once post-installation M&V and final savings calculations have been completed.	Analysis assumptions	Once Post-construction M&V and analysis have been completed

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1	Deemed savings claimed separately for VFDs based on standard efficiency fan. Deemed savings may be overstated. Note fan hp used in deemed savings calculations is incorrect	Analysis assumptions	
2			
3			
4			
5			
6			
7			
8			
9			
10			

