

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_T_C_202_PRJ - 01980874_Service
CMPA Directory Link	https://deeresources.info/cmpa/projects/15336
PA	PGE
PA Application ID	PRJ - 01980874
PA Application Executed Date	6/13/2019
PA Program ID	PGE210123
PA Program Name	Healthcare Energy Efficiency Program (HEEP)
PA Program Year	2019
Date of CPUC Staff Review:	11/5/2019
PA CMPA Upload Dates Included in this review:	
First PA Upload	8/6/2019
Second PA Upload	8/27/2019
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	installing insulation jackets on hot water/steam valves
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Install insulating jackets over the various steam pipes, valves, and steam traps.
PA Ex Ante kW Demand Reduction	0
PA Ex Ante Annual kWh Impacts	0
PA Ex Ante Annual Therm Impacts	13,752
PA Proposed Incentive \$ (to Customer)	\$6,876.23
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	0
CPUC Staff Approved Ex Ante Annual kWh Impacts	0
CPUC Staff Approved Ex Ante Annual Therm Impacts	13,752
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	Sugarpine Engineering
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	BMI
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
	Application ready to proceed without exception
x	Application ready to proceed with exception(s), as noted
	Application rejected.

	Application not ready for review, revised and resubmit as noted		
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date
	To ensure measure persistence for this project, please provide signage or other means directing insulation jackets to be replaced as soon as possible when removed for maintenance.	Baseline	N/A

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1	This disposition has been revised from 'rejected' status to 'application ready to proceed with exception(s) as noted'. A review of California OSHA regulations indicate that the baseline of no insulation for the proposed fittings is correct.		
2	For future similar projects, as was done for this project, please provide photographs showing non-insulated surfaces at minimum distances as specified in California OSHA regulations. If exceptions were requested from the regulation (eg. not possible to provide minimum safe distance), provide documented reasons for the exceptions in the project documentation package.		

