

## CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_T_C_202_PRJ - 01980874_Service
CMPA Directory Link	<a href="https://deeresources.info/cmpa/projects/15336">https://deeresources.info/cmpa/projects/15336</a>
PA	PGE
PA Application ID	PRJ - 01980874
PA Application Executed Date	6/13/2019
PA Program ID	PGE210123
PA Program Name	Healthcare Energy Efficiency Program (HEEP)
PA Program Year	2019
Date of CPUC Staff Review:	6/10/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	8/6/2019
Second PA Upload	8/27/2019
Third PA Upload	5/20/2020
PA Measure Description(s):	
Measure 1	installing insulation jackets on hot water/steam valves
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Install insulating jackets over the various steam pipes, valves, and steam traps.
PA Ex Ante kW Demand Reduction	0
PA Ex Ante Annual kWh Impacts	0
PA Ex Ante Annual Therm Impacts	13752
PA Proposed Incentive \$ (to Customer)	\$6,876.23
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	0
CPUC Staff Approved Ex Ante Annual kWh Impacts	0
CPUC Staff Approved Ex Ante Annual Therm Impacts	13715
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	BMI
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
<input checked="" type="checkbox"/>	Application ready to proceed without exception
<input type="checkbox"/>	Application ready to proceed with exception(s), as noted
<input type="checkbox"/>	Application rejected.

	Application not ready for review, revised and resubmit as noted		
<b>Action Number:</b>	<b>Summary of CPUC Staff Required Action by the PA:</b>	<b>Action Category</b>	<b>Due Date</b>
	Note: this is a post M&V review of a previously reviewed project. We reviewed all post installation material submitted by the PA and did not find any issues. The PA reduced the savings claim slightly due to reduced operating hours of the facility. Instructions noted in an exception (pre-install disposition) were followed.		N/A

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
-----------------------------	-----------------------------------	----------------------	----------

