

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_20_C_A_446_PRJ - 02224463_HVAC
CMPA Directory Link	#N/A
PA	PGE
PA Application ID	PRJ - 02224463
PA Application Executed Date	NA
PA Program ID	a0n3600000NcVkf
PA Program Name	Agricultural Calculated Incentives - Customized Incentive Program
PA Program Year	
Date of CPUC Staff Review:	6/1/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	3/28/2020
Second PA Upload	4/21/2020
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	PROCESS RETROFIT/NEW-FAN-EFFICIENT UNIT
Measure 2	PROCESS RETROFIT/NEW-FAN-VFD
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	NA
PA Ex Ante kW Demand Reduction	53.2
PA Ex Ante Annual kWh Impacts	289,980.0
PA Ex Ante Annual Therm Impacts	1.0
PA Proposed Incentive \$ (to Customer)	\$42,629.98
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0
CPUC Staff Approved Ex Ante kW Demand Reduction	
CPUC Staff Approved Ex Ante Annual kWh Impacts	
CPUC Staff Approved Ex Ante Annual Therm Impacts	
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW Consulting
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW Consulting
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
	Application ready to proceed without exception
	Application ready to proceed with exception(s), as noted
X	Application rejected.

Application not ready for review, revised and resubmit as noted			
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date
1	The scope of the project is not clear. The project documentation package does not include a narrative explaining what measures are, how they impact existing equipment and why New Construction MAT was selected. Please provide a narrative for the project to explain existing and installed equipment type, QTY, operation.	Missing required information	within 30 days of this disposition
2	According to some of the provided documentation the facility has enough existing ventilation fans for existing barns and these new high efficiency variable speed fans are replacing existing constant speed fans. This indicates that these are replacement measures. on the other hand, the calculation workbook has a note indication that the project involves load expansion. Please explain why NC is the appropriate MAT.	Measure Type	within 30 days of this disposition
3	Please explain why existing workpapers including "VSD for Ventilation Fan, Agricultural" and "Ventilation Fan, Agricultural" are not applicable to these measures.	PA program rules	within 30 days of this disposition

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

