

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_20_C_C_384_PRJ - 01991319_Service
CPMA Directory Link	https://deeresources.info/accounts/login?next=/cmpa/projects/15922
PA	PGE
PA Application ID	PRJ - 01991319
PA Application Executed Date	10/01/2019
PA Program ID	PGE21011
PA Program Name	Commercial Calculated Incentives - Customized Incentive Program
PA Program Year	2019
Date of CPUC Staff Review:	4/8/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	2/4/2020
Second PA Upload	2/25/2020
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	HVAC COOLING TOWERS - WATERSIDE ECONOMIZER - To-Code/Std
Measure 2	COMMISSIONING-RCX RESET CONTROL SETTING-HVAC-AIRFLOW
Measure 3	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SETPOINT CHANGE
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	RCx targeting CHW plant, AHUs and select lab spaces (focusing on CRAH & IRC optimization) in a high tech lab.
PA Ex Ante kW Demand Reduction	375.0
PA Ex Ante Annual kWh Impacts	3,935,770.0
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$264,271.20
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	375.0
CPUC Staff Approved Ex Ante Annual kWh Impacts	3,935,770.0
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW
PA Primary Reviewer Name	

PA Primary Reviewer Firm		
CPUC Staff Project Manager		
CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
<input checked="" type="checkbox"/>	Application ready to proceed without exception	
<input type="checkbox"/>	Application ready to proceed with exception(s), as noted	
<input type="checkbox"/>	Application rejected.	
<input type="checkbox"/>	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1	In the future, please provide a savings-weighted EUL for the entire project so that we can compare to the project-level simple payback. We calculated the weighted project EUL to be 5.4 yrs, which exceeds the project-level payback of 3.4 yrs.	
2		
3		
4		
5		
6		
7		
8		
9		
10		

