

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE 20 P C 390 PRJ - 02199935 Lighting
CMPA Directory Link	https://deeresources.info/accounts/login?next=/cmpa/projects/15934
PA	PGE
PA Application ID	PRJ - 02199935
PA Application Executed Date	12/30/2019
PA Program ID	PGE211028
PA Program Name	Yolo Energy Watch
PA Program Year	2019
Date of CPUC Staff Review:	3/17/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	2/4/2020
Second PA Upload	n/a
Third PA Upload	n/a
PA Measure Description(s):	
Measure 1	Lighting Retrofit/New-Interior-LED-General/Area Lighting
Measure 2	Lighting Retrofit/New-Exterior-LED-Pole Mounted
Measure 3	Lighting Retrofit/New-Exterior-LED-Wall Mounted
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	LED Mag Strips replacing high wattage T8's
PA Ex Ante kW Demand Reduction	1.1
PA Ex Ante Annual kWh Impacts	67,011.1
PA Ex Ante Annual Therm Impacts	-21.9
PA Proposed Incentive \$ (to Customer)	\$8,200.56
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0
CPUC Staff Approved Ex Ante kW Demand Reduction	1.1
CPUC Staff Approved Ex Ante Annual kWh Impacts	67,011.1
CPUC Staff Approved Ex Ante Annual Therm Impacts	-21.9
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW Consulting
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	Energy 350
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	

CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
X	Application ready to proceed without exception	
	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1	For AR projects, we recommend including photos of lighting with the fixtures in operation. The project documentation has photos of light fixtures that are not ON. If fixtures are not ON then these photos do not support that the existing fixtures operate.	Photo evidence of equipment viability not provided
2	One of the measures has a negative incremental cost in the Modified Lighting Calculator. Overall project does not have a negative incremental cost though.	Incremental Cost
3		
4		
5		
6		
7		
8		
9		
10		

