

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE 20 P C 391 PRJ - 02201845 Lighting
CMPA Directory Link	https://deeresources.info/accounts/login?next=/cmpa/projects/15936
PA	PGE
PA Application ID	PRJ - 02201845
PA Application Executed Date	12/16/2019
PA Program ID	PGE210143
PA Program Name	Hospitality 2016-19
PA Program Year	2019
Date of CPUC Staff Review:	3/10/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	1/28/2020
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	Lighting Retrofit/New-Exterior-LED-Pole Mounted
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Replaced/Retrofit (36) MH 250W 1L with (36) LED Retrofit Area Light 120W ESL Vision at a Office - Large (OFL) facility
PA Ex Ante kW Demand Reduction	0.0
PA Ex Ante Annual kWh Impacts	116,390.8
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$13,966.90
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	0.0
CPUC Staff Approved Ex Ante Annual kWh Impacts	116,390.8
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW Consulting
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW Consulting
PA Primary Reviewer Name	

PA Primary Reviewer Firm		
CPUC Staff Project Manager		
CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
<input checked="" type="checkbox"/>	Application ready to proceed without exception	
<input type="checkbox"/>	Application ready to proceed with exception(s), as noted	
<input type="checkbox"/>	Application rejected.	
<input type="checkbox"/>	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1	Reminder: Pre-install photos should show existing lighting in operation (ie with lights on).	Missing documents
2		
3		
4		
5		
6		
7		
8		
9		
10		

