

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE 20 P C 511 PRJ - 02226334 Lighting	
CMPA Directory Link	https://deeresources.info/cmpa/projects/17325	
PA	PGE	
PA Application ID	PRJ - 02226334	
PA Application Executed Date	0	
PA Program ID	a0n1R00001MaD4i	
PA Program Name	LGEAR - Staples Direct Install	
PA Program Year	1900	
Date of CPUC Staff Review:	6/26/2020	
PA CMPA Upload Dates Included in this review:		
First PA Upload	6/2/2020	
Second PA Upload	6/18/2020	
Third PA Upload	N/A	
PA Measure Description(s):		
Measure 1	LIGHTING RETROFIT/NEW-INT-LED-OTHER	
Measure 2	LIGHTING RETROFIT/NEW-INT-LED-GENERAL/AREA LIGHTING	
Measure 3	LIGHTING RETROFIT/NEW-EXT-LED-POLE MOUNTED	
Measure 4		
Measure 5		
Measure 6		
Measure 7		
Measure 8		
Measure 9		
Measure 10		
PA Project Description:	0	
PA Ex Ante kW Demand Reduction	2.3	
PA Ex Ante Annual kWh Impacts	22,192.7	
PA Ex Ante Annual Therm Impacts	-42.5	
PA Proposed Incentive \$ (to Customer)	\$3,901.52	
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0	
CPUC Staff Approved Ex Ante kW Demand Reduction		
CPUC Staff Approved Ex Ante Annual kWh Impacts		
CPUC Staff Approved Ex Ante Annual Therm Impacts		
CPUC Staff Primary Reviewer Name		
CPUC Staff Primary Reviewer Firm	E350	
CPUC Staff Review Supervisor Name		
CPUC Staff Review Supervisor Firm	SBW	
PA Primary Reviewer Name		
PA Primary Reviewer Firm		
CPUC Staff Project Manager		
CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
	Application ready to proceed without exception	
X	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category
		Due Date

1	Savings included in the bi-monthly submission does not match savings estimated in the MLC. Please either update savings in the quarterly submission or provide an updated version of MLC that matches savings included in bi-monthly submission.	Missing documents	within 30 days of this disposition
2	Please update the RUL of existing fixtures based on the EUL of the same type of equipment. The project is currently using the EUL of installed equipment (LED fixtures) to estimate the RUL of existing equipment.	EUL/RUL	within 30 days of this disposition

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

