

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_20_T_A_389_PRJ - 02173816 HVAC
CPMA Directory Link	https://deeresources.info/accounts/login?next=/cmpa/projects/15932
PA	PGE
PA Application ID	PRJ - 02173816
PA Application Executed Date	12/04/2019
PA Program ID	PGE210312
PA Program Name	CLEARresult Dairy & Winery Industry Efficiency Solutions Program
PA Program Year	2019
Date of CPUC Staff Review:	3/10/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	1/28/2020
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	PROCESS RETROFIT/NEW-FAN-EFFICIENT UNIT
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Install a total of (76) 72-inch and (60) 50-inch high efficiency fans in free stalls at a Dairy.
PA Ex Ante kW Demand Reduction	30.8
PA Ex Ante Annual kWh Impacts	74,435.4
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$13,544.75
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	30.8
CPUC Staff Approved Ex Ante Annual kWh Impacts	74,435.4
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	

CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
x	Application ready to proceed without exception	
	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		

