

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_20_T_C_428_PRJ - 02264467_Lighting
CMPA Directory Link	#N/A
PA	PGE
PA Application ID	PRJ - 02264467
PA Application Executed Date	03/22/2019
PA Program ID	PGE211024
PA Program Name	San Francisco Energy Watch
PA Program Year	2019
Date of CPUC Staff Review:	4/27/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	3/17/2020
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	Lighting Retrofit/New-Exterior-LED-Other
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Replace (12) 1-lamp MH fixtures with 1-lamp LED fixtures in SCn -
PA Ex Ante kW Demand Reduction	1.0
PA Ex Ante Annual kWh Impacts	17,614.6
PA Ex Ante Annual Therm Impacts	1.0
PA Proposed Incentive \$ (to Customer)	\$2,114.63
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0
CPUC Staff Approved Ex Ante kW Demand Reduction	
CPUC Staff Approved Ex Ante Annual kWh Impacts	
CPUC Staff Approved Ex Ante Annual Therm Impacts	
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW Consulting
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW Consulting
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
	Application ready to proceed without exception
	Application ready to proceed with exception(s), as noted
X	Application rejected.

Application not ready for review, revised and resubmit as noted			
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date
1	Estimated annual savings of 17,614 kWh is greater than total building annual consumption of 15,527 kWh, based on utility bills submitted as part of the project package. Please update savings to include MLC v12 capping analysis.	Calculation method	Within one month of this disposition
2	Please note that the project uses EUL of installed equipment to estimate RUL of existing equipment. The RUL should equal to 1/3 of EUL of existing equipment.	EUL/RUL	

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

