

## CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE 20 T C 513 PRJ - 02285598 Lighting				
CPMA Directory Link	<a href="https://deeresources.info/cmpa/projects/17331">https://deeresources.info/cmpa/projects/17331</a>				
PA	PGE				
PA Application ID	PRJ - 02285598				
PA Application Executed Date	0				
PA Program ID	aOn1R00001ZoU5j				
PA Program Name	Hospitality Program - Custom Direct Install				
PA Program Year	1900				
Date of CPUC Staff Review:	7/17/2020				
PA CMPA Upload Dates Included in this review:					
First PA Upload	6/2/2020				
Second PA Upload	N/A				
Third PA Upload	N/A				
PA Measure Description(s):					
Measure 1	LIGHTING RETROFIT/NEW-EXT-LED-POLE MOUNTED				
Measure 2	LIGHTING RETROFIT/NEW-INT-LED-GENERAL/AREA LIGHTING				
Measure 3	LIGHTING RETROFIT/NEW-INT-LED-RECESSED DOWNLIGHTS				
Measure 4					
Measure 5					
Measure 6					
Measure 7					
Measure 8					
Measure 9					
Measure 10					
PA Project Description:	0				
PA Ex Ante kW Demand Reduction	6.3				
PA Ex Ante Annual kWh Impacts	101,495.3				
PA Ex Ante Annual Therm Impacts	0.0				
PA Proposed Incentive \$ (to Customer)	\$13,116.94				
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0				
CPUC Staff Approved Ex Ante kW Demand Reduction					
CPUC Staff Approved Ex Ante Annual kWh Impacts					
CPUC Staff Approved Ex Ante Annual Therm Impacts					
CPUC Staff Primary Reviewer Name					
CPUC Staff Primary Reviewer Firm	E350				
CPUC Staff Review Supervisor Name					
CPUC Staff Review Supervisor Firm	SBW				
PA Primary Reviewer Name					
PA Primary Reviewer Firm					
CPUC Staff Project Manager					
CPUC Staff Policy Authorization (as needed)					
CPUC Staff Recommendation Marked "X":					
X	Application ready to proceed without exception				
	Application ready to proceed with exception(s), as noted				
	Application rejected.				
	Application not ready for review, revised and resubmit as noted				
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date	PA Response	CPUC Staff

1	Please correct RUL values assigned to each measure. The project uses 1/3 of EUL of installed equipment to estimate the RUL of the existing equipment. The appropriate EUL IDs to use for existing equipment are "OLtg-HID", "ILtg-Lfluor-Elec" and "ILtg-CFL-Com" for measures 1 through 3. Using 1/3 of EUL values for these EUL IDs for the appropriate building type, the RUL of measures 1 through 3 would be 5, 5, and 2.1 years. The project uses 4 years for all three measures.	EUL/RUL	Within 1 months of this disposition	Updated RUL	These updates are appropriate. No other action is required.

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date		
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					

