

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_20_T_I_381_PRJ - 01194737_Process
CPMA Directory Link	https://deeresources.info/accounts/login?next=/cpma/projects/15916
PA	PGE
PA Application ID	PRJ - 01194737
PA Application Executed Date	11/27/2019
PA Program ID	PGE21027
PA Program Name	Heavy Industry Energy Efficiency Program - Customized Retrofit
PA Program Year	2019
Date of CPUC Staff Review:	3/2/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	1/21/2020
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	PROCESS RETROFIT/NEW-CHILLERS/COOLING-EFFICIENT CHILLER OR COMPRESSOR
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Accelerated replacement of an existing 250 ton water cooled screw process chiller at a bottling plant with a more efficient 160 ton water cooled VFD centrifugal chiller.
PA Ex Ante kW Demand Reduction	17.6
PA Ex Ante Annual kWh Impacts	292,319.9
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$37,718.39
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	17.6
CPUC Staff Approved Ex Ante Annual kWh Impacts	292,319.9
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	

CPUC Staff Review Supervisor Firm	SBW	
PA Primary Reviewer Name		
PA Primary Reviewer Firm		
CPUC Staff Project Manager		
CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
x	Application ready to proceed without exception	
	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		

