

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_20_T_I_417_PRJ - 01924577_Service
CMPA Directory Link	https://deeresources.info/accounts/login?next=/cmpa/projects/16079
PA	PGE
PA Application ID	PRJ - 01924577
PA Application Executed Date	09/30/2019
PA Program ID	PGE21027
PA Program Name	Heavy Industry Energy Efficiency Program - Retro Commissioning (RCx)
PA Program Year	2019
Date of CPUC Staff Review:	4/20/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	2/25/2020
Second PA Upload	3/10/2020
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	COMMISSIONING-RCX RECODE CONTROLS-PROCESS-OTHER
Measure 2	COMMISSIONING-RCX RECODE CONTROLS-HVAC-OTHER
Measure 3	COMMISSIONING-RCX RECODE CONTROLS-HVAC-OTHER
Measure 4	COMMISSIONING-RCX RECODE CONTROLS-HVAC-OTHER
Measure 5	COMMISSIONING-RCX RECODE CONTROLS-HVAC-SCHEDULE CHANGE
Measure 6	COMMISSIONING-RCX RECODE CONTROLS-HVAC-
Measure 7	COMMISSIONING-RCX RECODE CONTROLS-HVAC-
Measure 8	COMMISSIONING-RCX RECODE CONTROLS-HVAC-AIRFLOW
Measure 9	COMMISSIONING-RCX RECODE CONTROLS-PROCESS-OTHER
Measure 10	COMMISSIONING-RCX RECODE CONTROLS-PROCESS-OTHER
PA Project Description:	Retro-commissioning of HVAC controls on eleven air handling units
PA Ex Ante kW Demand Reduction	91.2
PA Ex Ante Annual kWh Impacts	835,915.4
PA Ex Ante Annual Therm Impacts	2,830.3
PA Proposed Incentive \$ (to Customer)	\$40,073.22
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0
CPUC Staff Approved Ex Ante kW Demand Reduction	
CPUC Staff Approved Ex Ante Annual kWh Impacts	
CPUC Staff Approved Ex Ante Annual Therm Impacts	
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW Consulting
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW Consulting
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
	Application ready to proceed without exception
X	Application ready to proceed with exception(s), as noted
	Application rejected.

	Application not ready for review, revised and resubmit as noted		
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date
	Please provide trued up calculations using post-installation data. We would like to review updated calculations after post-installation M&V data has been collected.	Analysis assumptions	

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

