



**Memo**

1111 Broadway, Suite 1800  
Oakland, CA 94607  
510.844.2800 Tel  
www.itron.com

**Date:** August 31, 2012

**To:** Randy Kwok, Pacific Gas & Electric

**From:** Joseph Ball, Itron/ Keith Rothenberg Energy Metrics

**RE:** Data Request to Support Savings Claim for PGE 2K12079864 (EEGA 1936)

---

This request is focused on one particular application undergoing ex ante review:

- PGE 2K12079864 as part of the Customized Calculated Incentive Program

The project has been conditionally approved by ED. Refer to ex ante review report (X068 PGE 2K12079864 Phase 2 EAR 2012\_0831 ver 2.docx and X068 PGE 2K1209864 ED Calculation 2012\_0831.xlsx) for the full requirements and context of this request.

In order to complete an ex ante review the ED requests that PG&E submit the following documents as they become available:

1. Measure EUL.
2. Measure NTG ratio.
3. Post installation inspection report.
4. Documentation such as manually-entered chiller logs or data from the new chiller control panel showing the new chiller to be continuously energized and operating as the lead chiller since start up for a minimum of 30 days.
5. Verification that the chiller performance data matches the model of chiller approved/installed.
6. Final cost documentation

**Itron requests this information as it becomes available.** Your full and prompt response to this data request is appreciated, as Itron is attempting to provide timely feedback to PG&E on the savings claim for this application. The requested information should be provided electronically.

If you have any questions or need additional information, please do not hesitate to ask.

Please send requested information by posting on EEGA or other secure website.