



Memo

1111 Broadway, Suite 1800
Oakland, CA 94607
510.844.2800 Tel
www.itron.com

Date: September 10, 2012

To: Randy Kwok, Pacific Gas & Electric

From: Joseph Ball, Itron Keith Rothenberg Energy Metrics

RE: Data Request to Support Savings Claim for PGE 2K12085717 (EEGA 2092)

This request is focused on one particular application undergoing ex ante review:

- PGE 2K12085717 as part of the Customized Incentive Program

Refer to ex ante review reports (X132 PGE 2K12085717 EAR 2012_0612 V2.docx and X132 PGE 2K12085717 Phase 2 EAR 2012_0910.docx) for the full requirements and context of this request.

The ex ante savings estimates are conditionally approved, pending post installation M&V and fulfillment of this data request. Additional documentation is needed to complete this review.

Ex ante values for this project will not be frozen until the project M&V has been completed.

In order to complete an ex ante review the ED requests that the IOU submit the following documentation as it becomes available:

1. Submit a detailed M&V plan for this project. The IOU will continue to work with ED to finalize the M&V plan.
2. Provide seven (7) days of pre-installation compressed air system pressure monitored upstream of the compressed air dryers if possible, or at the receiver.
3. Recommend to the customer the installation of either a compressed air flow meter or a tap in the main distribution line in an appropriate location to allow a temporary meter to be installed for post-installation air flow measurements.
4. Provide 28 days of post-installation data for the compressed air system including compressor kW and system pressure measured at the same point as for the pre-installation measurement. Provide the compressed air flow measurements if possible.
5. Provide 28 days of post-installation production data, either hourly production data or data by shift, for the facility.
6. Provide the specifications for the new air compressor.
7. Submit the post-installation inspection report.

8. Provide final cost documentation.

ED is likely to ask for further clarifications and additional information as the details of this project become more clearly defined. ED requests that the IOU:

1. Keep ED informed of the progress and next steps on this project.
2. Inform ED of any future site visits including the post-installation inspection, with sufficient lead time, in case it chooses to send a representative on-site.
3. Provide sufficient opportunity for ED to review the requested data, analysis and calculations prior to the freezing of ex ante savings impacts for this project.

Itron requests this information as it becomes available. Your full and prompt response to this data request is appreciated, as Itron is attempting to provide timely feedback to PG&E on the savings claim for this application. The requested information should be provided electronically.

If you have any questions or need additional information, please do not hesitate to ask.

Please send requested information by posting on EEGA or other secure website.