

## CPUC Staff Ex Ante Review

|   |   |
|---|---|
| CPUC Staff Project ID Number                  | SCE 21 T C 696 [REDACTED]   |
| CMPA Directory Link                           | <a href="https://deeresources.info/cmpa/projects/19214">https://deeresources.info/cmpa/projects/19214</a>   |
| PA  | SCE   |
| PA Application ID                             | [REDACTED]  |
| PA Application Executed Date                  |   |
| PA Program ID                                 | SCE-13-TP-010   |
| PA Program Name                               | Plastics, Materials, and Basic Forms and Shapes Wholesalers   |
| PA Program Year                               |   |
| Date of CPUC Staff Review:                    |   |
| PA CMPA Upload Dates Included in this review: |   |
| First PA Upload                               | 8/31/2021   |
| Second PA Upload                              | N/A   |
| Third PA Upload                               | N/A   |
| Fourth PA Upload                              |   |
| Fifth PA Upload                               |   |
| Sixth PA Upload                               |   |
| Seventh PA Upload                             |   |
| Eighth PA Upload                              |   |
| PA Measure Description(s):                    |   |
| Measure 1                                     | Injection molder barrel insulation - add-on equipment   |
| Measure 2                                     |   |
| Measure 3                                     |   |
| Measure 4                                     |   |
| Measure 5                                     |   |
| Measure 6                                     |   |
| Measure 7                                     |   |
| Measure 8                                     |   |
| Measure 9                                     |   |
| Measure 10                                    |   |
| PA Project Description:                       | The measure will install insulation in the barrels of the seventeen injection molding machines. This measure is expected to improve the energy efficiency of the plastic injection process by reducing the heat loss to the ambient space where the machines are located. |
| Bi-Monthly Upload kW Demand Reduction         | [REDACTED]  |
| Bi-Monthly Upload Annual kWh Impacts          | [REDACTED]  |
| Bi-Monthly Upload Therm Impacts               | [REDACTED]  |
| PA Proposed Incentive \$ (to Customer)        | [REDACTED]  |
| Project Documentation kW Demand Reduction     | [REDACTED]  |
| Project Documentation Annual kWh Impacts      | [REDACTED]  |
| Project Documentation Annual Therm Impacts    | [REDACTED]  |
| CPUC Staff Primary Reviewer Name              | [REDACTED]  |
| CPUC Staff Primary Reviewer Firm              | [REDACTED]  |
| CPUC Staff Review Supervisor Name             | [REDACTED]  |
| CPUC Staff Review Supervisor Firm             | [REDACTED]  |
| PA Primary Reviewer Name                      |   |
| PA Primary Reviewer Firm                      |   |
| CPUC Staff Project Manager                    |   |
| CPUC Staff Policy Authorization (as needed)   |   |
| CPUC Staff Recommendation:                    | Application ready to proceed without exception  |
| For rejection, action required:               | N/A   |
| M&V Review:                                   | Post M&V Review NOT Required  |



| CPUC Staff Recommendation Definitions                    |  |
|--|--|
| CPUC Staff Recommendation                                | Definition   |
| Application ready to proceed without exception           | <p>The PA will continue to upload application documents to the CMPA directory through the implementation and claims phases of the project. The PA may proceed to approve the project without waiting for CPUC Staff response. A project is waived from further review at the post-installation stage by CPUC staff, but the PA is responsible for post-installation (IR) review. There will not be conditional approval.</p>   |
| Application ready to proceed with exception(s), as noted | <p>The PA must make revisions or changes as noted in CPUC Staff's review comments before signed agreement with customer. The PA will continue to upload application documents to the CMPA directory through the implementation and claims phases of the project. The PA may proceed to approve the project without waiting for CPUC Staff response. If CPUC Staff decides to perform IR review of a project, CPUC Staff will notify the PA. The scope will be limited to determine if the project was carried out consistent with the application and notes provided during pre-installation review and to obtain information pertaining to whether the eligibility criteria or metrics should be revised.</p> <p>Unless the scope of work presented in project application has changed at IR review, the project will not be reviewed again in the areas specified below. Scope change is defined by substantial changes include significant modifications to the proposed equipment type, size, quantity, configuration, the expansion of a project to include additional retrofits, or the splitting of a project into multiple phases.</p> <p>The following areas will not be reviewed again by CPUC Staff:</p> <ul style="list-style-type: none"> <li>• Calculation Tool</li> <li>• Calculation Methodology</li> <li>• M&amp;V Plan</li> <li>• Baseline</li> <li>• Eligibility</li> <li>• EUL/RUL</li> <li>• Measure Type</li> <li>• Program Influence</li> </ul> |
| Application rejected.                                    | <p>The application is rejected as submitted. The PA shall promptly inform the applicant as to the reasons why the project was rejected and the specific recommendations for the conditions under which the project would be approved. CPUC Staff shall provide the reasons for the rejection or request for modification, including each basis as to why the project is rejected, or modification is requested. In addition, CPUC Staff shall provide specific recommendations for the conditions under which the project would be approved.</p> <p>If any party to the project is unsatisfied with the Commission's directions for the project, a dispute resolution process may be initiated by that party. The Commission shall adopt rules for the conduct of the dispute resolution process. – Section 381.2 (g) (3) (F)</p>  |