

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_C_C_279_PRJ - 01949656_BldgEnvlp
CMPA Directory Link	https://deeresources.info/cmpa/projects/15636
PA	PGE
PA Application ID	PRJ - 01949656
PA Application Executed Date	8/28/2019
PA Program ID	PGE21011
PA Program Name	Commercial Calculated Incentives - Customized Incentive Program
PA Program Year	2019
Date of CPUC Staff Review:	11/26/2019
PA CMPA Upload Dates Included in this review:	
First PA Upload	10/15/2019
Second PA Upload	#N/A
Third PA Upload	#N/A
PA Measure Description(s):	
Measure 1	HVAC RETROFIT/NEW-ENVELOPE-WINDOWS-INSTALL WINDOW FILM
Measure 2	HVAC RETROFIT/NEW-ENVELOPE-WINDOWS-INSTALL WINDOW FILM
Measure 3	HVAC RETROFIT/NEW-ENVELOPE-WINDOWS-INSTALL WINDOW FILM
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Install V33 window film on 3 joined 7 story office buildings totaling
PA Ex Ante kW Demand Reduction	77.0
PA Ex Ante Annual kWh Impacts	205,015.0
PA Ex Ante Annual Therm Impacts	-2,506.0
PA Proposed Incentive \$ (to Customer)	\$33,019.30
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	
CPUC Staff Approved Ex Ante Annual kWh Impacts	
CPUC Staff Approved Ex Ante Annual Therm Impacts	
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	BMI
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
	Application ready to proceed without exception
	Application ready to proceed with exception(s), as noted
x	Application rejected.
	Application not ready for review, revised and resubmit as noted

Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category	Due Date
1	Savings and incentive amount in project Technical Review report do not match the values reported in the bimonthly upload. Please reconcile the differences and revise the bimonthly upload as needed.	Other - discrepancy with bimonthly upload	
2	Savings from eQUEST models updated by the Technical Reviewer do not match the values in the Technical Review report. Please verify the correct eQUEST models were submitted and/or revise Technical Report as necessary to resolve conflict.	Analysis assumptions	
3	Gas impacts were not updated by the Technical Reviewer. Please revise the gas impacts to incorporate model changes made during Technical Review.	Analysis assumptions	

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1	EUL increase to 15 yr based on 15 yr full material and labor warranty is approved.		
2			
3			
4			
5			
6			
7			
8			
9			
10			

