

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_P_C_218_a0n0g000009ZjXi_Lighting
CPMA Directory Link	https://deeresources.info/cmpa/projects/15375
PA	PGE
PA Application ID	PRJ - 01961638
PA Application Executed Date	5/17/2019
PA Program ID	PGE211007
PA Program Name	Association of Monterey Bay Area Governments (AMBAG) -Custom DI
PA Program Year	2019
Date of CPUC Staff Review:	10/8/2019
PA CMPA Upload Dates Included in this review:	
First PA Upload	8/20/2019
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	LIGHTING RETROFIT/NEW-INT LED HIGHBAY
Measure 2	BASIC LIN LED T8 REPLACEMENT LAMP NON-DIMM RETROFIT KITS
Measure 3	LIGHTING RETROFIT/NEW-EXT-LED-POLE MOUNTED
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Â Replace (304) T12, T8, and T5 linear fluorescent lamps, (47) exterior High Pressure Sodium and Metal Halide lamps/ballasts, and (7) high bay fixtures with LEDs in a food processing plant.
PA Ex Ante kW Demand Reduction	26.1
PA Ex Ante Annual kWh Impacts	191,576.7
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$38,481.38
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	26.1
CPUC Staff Approved Ex Ante Annual kWh Impacts	191,576.7
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	SBW
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	BMI
PA Primary Reviewer Name	
PA Primary Reviewer Firm	

CPUC Staff Project Manager		
CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
	Application ready to proceed without exception	
x	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category
1	Please provide PI certification of permitting. Since this is a DI project, the PI (Ecology Action) handles the permitting; and provides certification that the proper permits were obtained and a licensed contractor was used.	Missing documents

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1	Project documentatation package provided the PA Tech review as the Project Summary. Is there a separate Project Summary document? If so, please check the documentation assembly process and reconcile going forward.	Missing documents

