

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_P_C_313_PRJ - 02129832_Lighting
CPMA Directory Link	https://deeresources.info/cmpa/projects/15748
PA	PGE
PA Application ID	PRJ - 02129832
PA Application Executed Date	10/3/2019
PA Program ID	PGE210111
PA Program Name	Hospitality 2016-19
PA Program Year	2019
Date of CPUC Staff Review:	2/11/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	11/19/2019
Second PA Upload	12/24/2019
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	LIGHTING RETROFIT/NEW-EXT-LED-POLE MOUNTED
Measure 2	LIGHTING RETROFIT/NEW-EXT-LED-WALL MOUNTED
Measure 3	Lighting Retrofit/New-Ext-LED-Other
Measure 4	LIGHTING RETROFIT/NEW-INT-LED-GENERAL/AREA LIGHTING
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Replaced/Retrofit (9) MH 150w 1L with (9) LED Area 25w 4000K Type 3 (70-120w HID) NBAL NebuLite at a Lodging - Hotel (HTL) facility
PA Ex Ante kW Demand Reduction	0.2
PA Ex Ante Annual kWh Impacts	9,149.7
PA Ex Ante Annual Therm Impacts	-8.5
PA Proposed Incentive \$ (to Customer)	\$1,132.91
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	0.2
CPUC Staff Approved Ex Ante Annual kWh Impacts	9,149.7
CPUC Staff Approved Ex Ante Annual Therm Impacts	-8.5
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW
PA Primary Reviewer Name	
PA Primary Reviewer Firm	

CPUC Staff Project Manager		
CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
	Application ready to proceed without exception	
x	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category
	We believe the RUL for this project to be defined as 1/3 the EUL, but this is not explicitly stated in documentation. Please confirm.	EUL/RUL

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
-----------------------------	-----------------------------------	----------------------

