

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_P_C_329_PRJ - 02135474_Lighting
CPMA Directory Link	https://deeresources.info/cmpa/projects/15763
PA	PGE
PA Application ID	PRJ - 02135474
PA Application Executed Date	9/9/2019
PA Program ID	PGE211009
PA Program Name	East Bay Energy Watch
PA Program Year	2019
Date of CPUC Staff Review:	1/28/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	12/4/2019
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	Lighting Retrofit/New-Interior-LED-General/Area Lighting
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Retrofit (26) 4L 4' T12 w LED troffer
PA Ex Ante kW Demand Reduction	3.1
PA Ex Ante Annual kWh Impacts	10,798.6
PA Ex Ante Annual Therm Impacts	-61.0
PA Proposed Incentive \$ (to Customer)	\$2,651.72
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	3.1
CPUC Staff Approved Ex Ante Annual kWh Impacts	10,798.6
CPUC Staff Approved Ex Ante Annual Therm Impacts	-61.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	BMI
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	
CPUC Staff Recommendation Marked "X":	
<input checked="" type="checkbox"/>	Application ready to proceed without exception
<input type="checkbox"/>	Application ready to proceed with exception(s), as noted
<input type="checkbox"/>	Application rejected.
<input type="checkbox"/>	Application not ready for review, revised and resubmit as noted

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category	Due Date
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

