

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_P_C_335_PRJ - 02155375_Lighting
CPMA Directory Link	https://deeresources.info/cmpa/projects/15799
PA	PGE
PA Application ID	
PA Application Executed Date	43774
PA Program ID	PGE210143
PA Program Name	Hospitality 2016-19
PA Program Year	2019
Date of CPUC Staff Review:	3/3/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	12/17/2019
Second PA Upload	1/15/2020
Third PA Upload	n/a
PA Measure Description(s):	
Measure 1	Lighting Retrofit/New-Exterior-LED-Other
Measure 2	Lighting Retrofit/New-Interior-LED-General/Area Lighting
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Replaced/Retrofit (8) MH 400W 1L with (8) LED Fixture Flood 150W
PA Ex Ante kW Demand Reduction	0.2
PA Ex Ante Annual kWh Impacts	13,310.2
PA Ex Ante Annual Therm Impacts	-3.5
PA Proposed Incentive \$ (to Customer)	\$1,624.80
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	0
CPUC Staff Approved Ex Ante kW Demand Reduction	0.2
CPUC Staff Approved Ex Ante Annual kWh Impacts	13,310.2
CPUC Staff Approved Ex Ante Annual Therm Impacts	-3.5
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	Energy 350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	Energy 350
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	

CPUC Staff Recommendation Marked "X":		
X	Application ready to proceed without exception	
	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		

