

## CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_T_C_283_O-065267_Lighting
CMPA Directory Link	<a href="https://deeresources.info/cmpa/projects/15640">https://deeresources.info/cmpa/projects/15640</a>
PA	PGE
PA Application ID	PRJ - 02086556
PA Application Executed Date	9/13/2019
PA Program ID	PGE21018
PA Program Name	EnergySmart Grocer - Customized Retrofit
PA Program Year	2019
Date of CPUC Staff Review:	11/22/2019
PA CMPA Upload Dates Included in this review:	
First PA Upload	10/15/2019
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	LIGHTING RETROFIT/NEW-INT-LED-OTHER
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Retrofit 1,197 interior fluorescent T8 fixtures (4,644 lamps) with a General Electric LED lighting technology in a 90,000 square foot grocery store.
PA Ex Ante kW Demand Reduction	44.7
PA Ex Ante Annual kWh Impacts	234,884.1
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$34,888.09
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	46.5
CPUC Staff Approved Ex Ante Annual kWh Impacts	218,843.7
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW
PA Primary Reviewer Name	

PA Primary Reviewer Firm		
CPUC Staff Project Manager		
CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
	Application ready to proceed without exception	
x	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
<b>Action Number:</b>	<b>Summary of CPUC Staff Required Action by the PA:</b>	<b>Action Category</b>
	Please update bi-monthly values to match technical review/MLC values.	Savings calculations
	Please provide a statement by the customer confirming the viability and continued intent to use the existing equipment. Note that this is required per the statewide guidance document for all accelerated replacement projects (see 2.4.2).	EUL/RUL

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		

