

## CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_T_I_238_WISE-125_Process
CPMA Directory Link	<a href="https://deeresources.info/cmpa/projects/15404">https://deeresources.info/cmpa/projects/15404</a>
PA	PGE
PA Application ID	PRJ - 02001745
PA Application Executed Date	6/27/2019
PA Program ID	PGE210135
PA Program Name	Water Infrastructure & system efficiency program - Customized Retrofit
PA Program Year	2019
Date of CPUC Staff Review:	11/5/2019
PA CMPA Upload Dates Included in this review:	
First PA Upload	9/10/2019
Second PA Upload	10/1/2019
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	PROCESS RETROFIT/NEW-PUMPS-MODIFY SYSTEM
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Pump Sequencing for a municipal water district
PA Ex Ante kW Demand Reduction	0.0
PA Ex Ante Annual kWh Impacts	271,763.4
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$32,611.61
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	64570.98
CPUC Staff Approved Ex Ante kW Demand Reduction	0.0
CPUC Staff Approved Ex Ante Annual kWh Impacts	271,763.4
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	
CPUC Staff Primary Reviewer Firm	E350
CPUC Staff Review Supervisor Name	
CPUC Staff Review Supervisor Firm	SBW
PA Primary Reviewer Name	
PA Primary Reviewer Firm	
CPUC Staff Project Manager	
CPUC Staff Policy Authorization (as needed)	

CPUC Staff Recommendation Marked "X":		
x	Application ready to proceed without exception	
	Application ready to proceed with exception(s), as noted	
	Application rejected.	
	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		

