

CPUC Staff Ex Ante Review

| | |
|---|---|
| CPUC Staff Project ID Number | PGE_19_T_C_312_PRJ - 02112758_Lighting |
| CPMA Directory Link | https://deeresources.info/cmpa/projects/15747 |
| PA | PGE |
| PA Application ID | PRJ - 02112758 |
| PA Application Executed Date | 9/5/2019 |
| PA Program ID | PGE211024 |
| PA Program Name | San Francisco Energy Watch |
| PA Program Year | 2019 |
| Date of CPUC Staff Review: | 12/18/2019 |
| PA CMPA Upload Dates Included in this review: | |
| First PA Upload | 11/12/2019 |
| Second PA Upload | N/A |
| Third PA Upload | N/A |
| PA Measure Description(s): | |
| Measure 1 | LED T8 Plug and Play |
| Measure 2 | |
| Measure 3 | |
| Measure 4 | |
| Measure 5 | |
| Measure 6 | |
| Measure 7 | |
| Measure 8 | |
| Measure 9 | |
| Measure 10 | |
| PA Project Description: | Replace 108 F32T8 with TLEDs in hotel space |
| PA Ex Ante kW Demand Reduction | 1.3 |
| PA Ex Ante Annual kWh Impacts | 9,321.9 |
| PA Ex Ante Annual Therm Impacts | -48.1 |
| PA Proposed Incentive \$ (to Customer) | \$3,180.34 |
| PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer) | |
| CPUC Staff Approved Ex Ante kW Demand Reduction | 3.2 |
| CPUC Staff Approved Ex Ante Annual kWh Impacts | 22,527.9 |
| CPUC Staff Approved Ex Ante Annual Therm Impacts | -116.2 |
| CPUC Staff Primary Reviewer Name | |
| CPUC Staff Primary Reviewer Firm | E350 |
| CPUC Staff Review Supervisor Name | |
| CPUC Staff Review Supervisor Firm | SBW |
| PA Primary Reviewer Name | |
| PA Primary Reviewer Firm | |
| CPUC Staff Project Manager | |

| | | |
|--|---|--|
| CPUC Staff Policy Authorization (as needed) | | |
| CPUC Staff Recommendation Marked "X": | | |
| | Application ready to proceed without exception | |
| x | Application ready to proceed with exception(s), as noted | |
| | Application rejected. | |
| | Application not ready for review, revised and resubmit as noted | |
| Action Number: | Summary of CPUC Staff Required Action by the PA: | Action Category |
| | Please provide pre-installation photos of existing equipment when available (submittal note indicates currently waiting on these). This is a requirement per customized rulebook. | Photo evidence of equipment viability not provided |
| | Please provide the RUL for this project. | EUL/RUL |

| Note or Instruction Number: | CPUC Staff Notes or Instructions: | Instruction Category |
|-----------------------------|---|----------------------|
| 1 | Savings and incentive have been updated to reflect final numbers. | |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |

