

CPUC Staff Ex Ante Review

CPUC Staff Project ID Number	PGE_19_T_I_360_PRJ - 01574806_Process
CMPA Directory Link	https://deeresources.info/accounts/login?next=/cmpa/projects/15878
PA	PGE
PA Application ID	PRJ - 01574806
PA Application Executed Date	07/30/2019
PA Program ID	PGE21027
PA Program Name	Heavy Industry Energy Efficiency Program - Customized Retrofit
PA Program Year	2019
Date of CPUC Staff Review:	2/18/2020
PA CMPA Upload Dates Included in this review:	
First PA Upload	1/7/2020
Second PA Upload	N/A
Third PA Upload	N/A
PA Measure Description(s):	
Measure 1	PROCESS COMPRESSED AIR - REPLACE AIR COMPRESSOR - To-Code/Std
Measure 2	
Measure 3	
Measure 4	
Measure 5	
Measure 6	
Measure 7	
Measure 8	
Measure 9	
Measure 10	
PA Project Description:	Replace one 75 hp fixed speed oil-flooded rotary screw compressor (with load/unload control) with one new 50hp variable speed drive (VSD) rotary screw compressor, in a food processing facility.
PA Ex Ante kW Demand Reduction	12.6
PA Ex Ante Annual kWh Impacts	81,993.0
PA Ex Ante Annual Therm Impacts	0.0
PA Proposed Incentive \$ (to Customer)	\$5,863.83
PA Proposed Total Payment to Implementer \$ (not to include the above incentive to customer)	
CPUC Staff Approved Ex Ante kW Demand Reduction	12.6
CPUC Staff Approved Ex Ante Annual kWh Impacts	81,993.0
CPUC Staff Approved Ex Ante Annual Therm Impacts	0.0
CPUC Staff Primary Reviewer Name	

CPUC Staff Primary Reviewer Firm	E350	
CPUC Staff Review Supervisor Name		
CPUC Staff Review Supervisor Firm	SBW	
PA Primary Reviewer Name		
PA Primary Reviewer Firm		
CPUC Staff Project Manager		
CPUC Staff Policy Authorization (as needed)		
CPUC Staff Recommendation Marked "X":		
<input checked="" type="checkbox"/>	Application ready to proceed without exception	
<input type="checkbox"/>	Application ready to proceed with exception(s), as noted	
<input type="checkbox"/>	Application rejected.	
<input type="checkbox"/>	Application not ready for review, revised and resubmit as noted	
Action Number:	Summary of CPUC Staff Required Action by the PA:	Action Category

Note or Instruction Number:	CPUC Staff Notes or Instructions:	Instruction Category
1	The reviewer noted that in some cases code exempts single compressor systems from VFD. Please confirm that no exemptions apply in this case and that standard practice is a compressor equipped with a VFD.	Baseline
2		
3		
4		
5		
6		
7		
8		
9		
10		

